A. FITTING OUT

- 1. The existing floor is to be kept. The new floor is to be made the same color of the existing one or as close image/color as possible.
- 2. We agree with the proposal.
- 3. What rear door on the second floor are in question? The drawings of the existing layouts of the building show no doors on the north side of the second floor.
- 4. The proposal for the panels and other materials and constructions are to be suggested by the contractor and submitted for approval.
- 5. Yes
- 6. What fabric do you have in mind?
- 7. Yes, ad are to be proposed by the Contractor.
- 8. In that case, the window mentioned should not be constructed; the ventilation of the toilet is to be designed for mechanical ventilation devices.
- 9. No, the contractor is to propose it.
- 10. Yes
- 11. Yes, they are to be opened from inside to outside due to the fire regulation principles / evacuation of people inside in the case of fire.

B. M&E

- 1. Distribution board equipped with main automatic circuit breaker with emergency push button in project are the usual concept.
- 2. Controller for frost protection system can be type DEVIREG 850, "DEVI DANFFOS GROUP".
- 3. The pipeline entry point have to be protected with hydro insulation and aluminum sheet.
- 4. The bill of quantities for M&E have not been done for this level of project.
- 5. The bill of quantities for HVAC have not been done for this level of project.
- 6. No
- 7. Yes, we agree with the proposal.

C. FIRE SERVICE/SECURITY

- 1. It is to be supplied by GC. The language on system displays is to be English.
- 2. The design of smoke alarm is to be based on European NM regulations.
- 3. It is to be supplied by GC. The language on system displays is to be English.

D. BILL OF QUANTITIES

- 1. Yes, it can be provided.
- 2. Yes, the tender could be modified and vindicated

E. TENDERER GENERAL INFORMATION

- Yes.
- 2. Yes, it reffers to the first four evidences requested at the Part 4. of Tender documents.